



(1) EC-TYPE-EXAMINATION CERTIFICATE (Translation)

- (2) Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres - Directive 94/9/EC
(3) EC-type-examination Certificate Number:

PTB 04 ATEX 1015



- (4) Equipment: Terminal box, types STB and NXT
(5) Manufacturer: COOPER CROUSE-HINDS GmbH
(6) Address: Neuer Weg Nord 49, 69412 Eberbach, Germany
(7) This equipment and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
(8) The Physikalisch-Technische Bundesanstalt, notified body No. 0102 in accordance with Article 9 of the Council Directive 94/9/EC of 23 March 1994, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmospheres, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report PTB Ex 04-14027.

- (9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

**EN 50014:1997 + A1 + A2 EN 50019:2000 EN 50020:2002
EN 50281-1-1:1998**

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
(11) This EC-type-examination Certificate relates only to the design, examination and tests of the specified equipment in accordance to the Directive 94/9/EC. Further requirements of the Directive apply to the manufacturing process and supply of this equipment. These are not covered by this certificate.
(12) The marking of the equipment shall include the following:


Ex II 2 G/D EEx e Ia II, IIC T6, T5 IP 66 T 80 °C, T 95 °C

Zertifizierungsstelle Explosionsschutz

Braunschweig, February 26, 2004

By order:

DR-Ing. U. Klausmeyer
Regierungsdirektor



sheet 1/3

EC-type-examination Certificates without signature and official stamp shall not be valid. The certificates may be circulated only without alteration. Extracts or alterations are subject to approval by the Physikalisch-Technische Bundesanstalt. In case of dispute, the German text shall prevail.

(13)

S C H E D U L E

(14)

EC-TYPE-EXAMINATION CERTIFICATE PTB 04 ATEX 1015

(15) Description of equipment

The terminal box, types STB and Typ NXT , consists of a stainless-steel enclosure designed to Increased Safety "e" type of protection or IP66.

It is to accommodate terminals for intrinsically safe and non-intrinsically safe circuits. The box area intended for intrinsically safe circuits is marked, e.g. by a light-blue colour. Connection is by means of explosion-proof cable entries.

The empty enclosure as well as all integrated elements and extension elements have been tested and certified under a separate examination certificate.

Technical data

Rated voltage, type NXT	up to	1100 V
Rated voltage, type STB	up to	750 V
Rated current	max.	500 A
Rated cross section	max.	240 mm ²

Rated values are maximum values, the actual electrical values are determined by mounted electrical apparatus. Within these limiting values complying with the appropriate standards the manufacturer specifies the final limiting values dependent on power supply specifications, operating mode, utilization category, etc.

Ambient temperature	-55 °C up to +55 °C (T5)
(sealing HT 100)	-55 °C up to +40 °C (T6)

Protection against contact, foreign bodies and water:	IP 66 according to EN 60529:1991
--	----------------------------------

The composition of the protection symbol will be based on the types of protection of components actually used.

(16) Test report PTB Ex 04-14027

(17) Special conditions for safe use

None;

Physikalisch-Technische Bundesanstalt



Braunschweig und Berlin

SCHEDULE TO EC-TYPE-EXAMINATION CERTIFICATE PTB 04 ATEX 1015

Notes for manufacturing and operation

For the maximum number of conductors for each enclosure size, which is subject to the cross section and the permissible continuous current, reference is made to the data sheets.

Equipment designed to Intrinsic Safety "i" type of protection shall be installed in such a way that, the clearance and creepage distances specified in EN 60079-14 between intrinsically safe and non-intrinsically safe circuits are complied with.

If the clearance requirements specified in EN 50020, section 6.3, are not complied with, terminals and wiring of Increased Safety "e" standard shall also be used for the intrinsically safe circuits.

When connecting more than one intrinsically safe circuit, the rules and regulations for interconnection shall be duly observed.

(18) Essential health and safety requirements

met by compliance with the standards mentioned above

Zertifizierungsstelle Explosionsschutz

By order:


Dr.-Ing. U. Klausmeyer
Regierungsdirektor

Braunschweig, February 26, 2004

Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

1. S U P P L E M E N T

according to Directive 94/9/EC Annex III.6

to EC-TYPE-EXAMINATION CERTIFICATE PTB 04 ATEX 1015

(Translation)

Equipment: Terminal boxes type STB and NXT

Marking:  II 2 G EEx e ia IIC T6, T5

 II 2 D IP66 T 80 °C, T 95 °C

Manufacturer: Cooper Crouse-Hinds GmbH

Address: Neuer Weg Nord 49, 69412 Eberbach, Germany

Description of supplements and modifications

The terminal boxes model STB and NXT are supplemented by following points:

1) They are extended by the types NXT 125 30 20 and NXT 120 100 30.

2) They will be extended by with the following types:

STBFB Installation of a field bus

STBSCS Control unit

NXTNCS Control unit

These types can be equipped with – separately certified – switching, control, adjusting and measuring units in addition.

3) The operating temperature range will be widened to max. -55 °C to +65 °C

4) They will be re-checked according to the standards EN 60079-0, EN 60079-7, EN 60079-11, EN 61241-0 and EN 61241-1.

The marking will thus change to:

 II 2 G Ex d e ia(ib) [ia(ib)] mb IIC T6, T5, T4

 II 2 D Ex tD A21 IP66 T 80 °C, T 95 °C, T 130 °C

Technical data

Sizes (all types)		Height	Width	Depth
	smallest	120 mm	120 mm	80 mm
	largest	1900 mm	1000 mm	300 mm

Sheet 1/2

EC-type-examination Certificates without signature and official stamp shall not be valid. The certificates may be circulated only without alteration. Extracts or alterations are subject to approval by the Physikalisch-Technische Bundesanstalt. In case of dispute, the German text shall prevail.

Physikalisch-Technische Bundesanstalt



Braunschweig und Berlin

1. SUPPLEMENT TO EC-TYPE-EXAMINATION CERTIFICATE PTB 04 ATEX 1015

Rated voltage type NXT	up to	1100 V
Rated voltage type STB	up to	750 V
Rated voltage type STBFB	up to	750 V
Rated voltage type STBSCS	up to	750 V
Rated voltage type NXTNCS	up to	750 V
Rated current	max.	500 A
Rated cross section	max.	240 mm ²

The rated values are maximum values. The actual electrical values will be determined by the installed electrical equipments. The manufacturer will define the final rated values in the scope of these limit values, while the applicable standards are maintained and depending on power supply conditions, operation mode and etc.

Ambient temperature range max.....-55 °C up to +65 °C

Protection against contact, dust and water:.....IP 66 according to EN 60529

The composition of the symbol specifying the type of protection depends on the types of protection of the components used.

Notes for manufacture and operation

The maximum number of the conductors per enclosure size depending on the cross section area and the allowed continuous current can be retrieved from the attached supplementary sheets.

The installation of the equipments in the type of ignition protection intrinsic safety "i" must be carried out in such a way that the distances, sparking distances in air and leakage distances between intrinsically safe and non-intrinsically safe electrical circuits required according to EN 60079-11 must be maintained.

If the distance requirements for the connected equipments according to EN 60079-11 are not ensured by the installation, then cables of the quality enhanced safety "e" should be used or the cables should be defined in a failsafe manner accordingly.

For use of more than one intrinsically safe electrical circuit, the rules of the interconnection should be observed.

Applied standards

EN 60079-0:2006

EN 60079-1:2007

EN 60079-7:2007

EN 60079-11:2007

EN 60079-18:2004

EN 61241-0:2006

EN 61241-1:2004

Test report: PTB Ex 08-18298

Zertifizierungssektor Explosionsschutz

By order:

Braunschweig, December 15, 2008

Dr.-Ing. M. Thedens
Oberregierungsrat



Sheet 2/2

EC-type-examination Certificates without signature and official stamp shall not be valid. The certificates may be circulated only without alteration. Extracts or alterations are subject to approval by the Physikalisch-Technische Bundesanstalt.
In case of dispute, the German text shall prevail.

Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Physikalisch-Technische Bundesanstalt • Postfach 33 45 • 38023 Braunschweig

Cooper-Crouse Hinds GmbH
z. Hd. Frau Frankhauser

Neuer Weg Nord 49
69412 Eberbach

Ihr Zeichen:

Ihre Nachricht vom: 29.11.2007

Unser Zeichen:

Unsere Nachricht vom:

Bearbeitet von: Dr. Monika Schumann
Telefonnummer: +49 (0) 531-592-3515
Telefaxnummer: +49 (0) 531-592-3505
E-Mail: Monika.Schumann@ptb.de

Datum: 14. Januar 2008

**Changing of the generation of the standards EN 60079-0 foll., EN 6124-0 foll.
Terminal box, types STB and Typ NXT,
PTB 04 ATEX 1015**

Dear Ms. Frankhauser,

there are no safety-related objections from PTB to mark
the Terminal box, types STB and Typ NXT as follows:

II 2 G Ex e ia IIC T6, T5

II 2 D Ex tD A21 IP66 T 80 °C, T 95 °C

Any components attached or installed have to be of a technical standard that complies with the specifications on the cover sheet. They must be suited for the operating conditions, and be covered by a separate examination certificate.

The rated voltage of the terminal box type STB is decreased to 690 V

We would like to ask you to include this change into the next supplement.

Mit freundlichen Grüßen
Im Auftrag

Schumann

Dr. Schumann
Regierungsrätin

Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Physikalisch-Technische Bundesanstalt • Postfach 33 45 • 38023 Braunschweig

Cooper-Crouse Hinds GmbH
z. Hd. Frau Frankhauser

Neuer Weg Nord 49
69412 Eberbach

Ihr Zeichen:
Ihre Nachricht vom: 29.11.2007
Unser Zeichen:
Unsere Nachricht vom:

Bearbeitet von: Dr. Monika Schumann
Telefondurchwahl: +49 (0) 531-592-3515
Telefaxdurchwahl: +49 (0) 531-592-3505
E-Mail: Monika.Schumann@ptb.de

Datum: 14. Januar 2008

**Normengenerationsänderung nach EN 60079-0 ff, EN 6124-0 ff
Klemmenkasten Typ STB und Typ NXT
PTB 04 ATEX 1015**

Sehr geehrte Frau Frankhauser,

es bestehen keine sicherheitstechnischen Bedenken,

den Klemmenkasten Typ STB und Typ NXT mit folgenden Kennzeichnungen zu versehen:

II 2 G Ex e ia IIC T6, T5

II 2 D Ex tD A21 IP66 T 80 °C, T 95 °C

Für den Ein- und Anbau sind nur Komponenten zugelassen, die dem auf dem Deckblatt angegebenen Normenstand technisch entsprechen, für die Einsatzbedingungen geeignet sind und eine gesonderte Bescheinigung besitzen.

Die Bemessungsspannung des Klemmenkastens Typ STB wird auf 690 V verringert.

Wir bitten Sie, diese Änderungen bei zukünftigen Ergänzungen mit aufzunehmen.

Mit freundlichen Grüßen
Im Auftrag

Dr. Schumann
Regierungsräatin

600000

Hausadresse, Lieferanschrift:
Bundesallee 100
38116 Braunschweig
Deutschland

Telefon (Zentrale): 0531 592-0
Telefax (Zentrale): 0531 592-9292
E-Mail (Zentrale): poststelle@ptb.de
Internet: <http://www.ptb.de>

Achtung! Neue Bankverbindung:

Bundeskasse Halle
Landeszentralbank Halle
Konto: 800 010 00
BLZ: 800 000 00

PTB Berlin-Charlottenburg
Abbestraße 2-12
10587 Berlin
Deutschland

Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Physikalisch-Technische Bundesanstalt, Postfach 33 45, 38023 Braunschweig

Cooper-Crouse Hinds GmbH
z. Hd. Herr Huter

Neuer Weg Nord 49
69412 Eberbach

Ihr Zeichen:
Ihre Nachricht vom: 20.04.2009
Mein Zeichen:
Meine Nachricht vom:

Bearbeitet von: Dr. Monika Schumann
Telefondurchwahl: +49 (0) 531-592-3515
Telefaxdurchwahl: +49 (0) 531-592-3505
E-Mail: Monika.Schumann@ptb.de

Datum: 24.04.2009

Klemmenkästen und Steuerkästen Typ STB und NXT, PTB 02 ATEX 1015

Sehr geehrter Herr Huter,

es bestehen keine sicherheitstechnischen Bedenken,

die oben genannten Klemmenkästen und Steuerkästen auch mit einer Tiefe von 340 mm zu fertigen.

Wir bitten Sie, diese Änderungen bei zukünftigen Ergänzungen mit aufzunehmen.

Translation

there are no safety-related objections from PTB

to produce the terminal box and control box mentioned above also with a depth of 340 mm.

We would like to ask you to include this change into the next supplement.

Mit freundlichen Grüßen
Im Auftrag

Dr. Schumann
Regierungsrätin

600 00

Hausadresse, Lieferanschrift: Telefon: +49 531 592-0
Bundesallee 100 Telefax: +49 531 592-9292
38116 Braunschweig E-Mail: poststelle@ptb.de
DEUTSCHLAND Internet: http://www.ptb.de

Deutsche Bundesbank, Filiale Dresden
Kto.-Nr.: 850 010 11 BLZ 850 000 00
IBAN: DE 23 8500 0000 0085 0010 11
BIC: MARKDEF1850, VAT-Nr.: DE 811 240 952

PTB Berlin-Charlottenburg
Abbestr. 2-12
10587 Berlin
DEUTSCHLAND

Physikalisch-Technische Bundesanstalt

Braunschweig und Berlin

Physikalisch-Technische Bundesanstalt • Postfach 33 45 • 38023 Braunschweig

Cooper-Crouse Hinds GmbH
z. Hd. Herrn Huter

Neuer Weg Nord 49
69412 Eberbach

Ihr Zeichen:
Ihre Nachricht vom: 06.10.2008
Unser Zeichen:
Unsere Nachricht vom:

Bearbeitet von: Dr. Monika Schumann
Telefondurchwahl: +49 (0) 531-592-3515
Telefaxdurchwahl: +49 (0) 531-592-3415
E-Mail: Monika.Schumann@ptb.de

Datum: 10.10.2008

Klemmenkasten Typ STB und Typ NXT PTB 04 ATEX 1015

Sehr geehrter Herr Huter,
es bestehen keine sicherheitstechnischen Bedenken,
den oben genannten Klemmenkasten auch in der Gehäusegröße
1250 x 300 x 200 mm zu fertigen.

Wir bitten Sie, diese Änderungen bei zukünftigen Ergänzungen mit aufzunehmen.

Mit freundlichen Grüßen

Im Auftrag

Schumann
Dr. Schumann
Regierungsrätin

600 00 g

Hausadresse, Lieferanschrift:
Bundesallee 100
38116 Braunschweig
Deutschland

Telefon (Zentrale): 0531 592-0
Telefax (Zentrale): 0531 592-9292
E-Mail (Zentrale): poststelle@ptb.de
Internet: <http://www.ptb.de>

Achtung! Neue Bankverbindung:

Bundeskasse Halle
Landeszentralbank Halle
Konto: 800 010 00
BLZ: 800 000 00

PTB Berlin-Charlottenburg
Abbestraße 2-12
10587 Berlin
Deutschland