DO NOT SCALE





EXTERNAL EARTH
STUD ASSEMBLY

1. TYPE XB9 IIC XENON BEACON
2. CERTIFICATION No. - BAS 00ATEX2031 EExd IIC T5 & T6
   T5 (T amb. -55°C to +55°C)
   T6 (T amb. -55°C to +40°C)
3. WEIGHT :- 1.6 ± 0.3 KG
4. ENCLOSURE & COVER MATERIAL - GLASS REINFORCED POLYESTER
5. OPTIONAL DUTY TAG/LABEL
6. TERMINALS SUITABLE FOR UP TO 3 WAY MAX 2.5mm^2
7. CABLE ENTRY - EITHER 1 OFF M20, PG13.5 OR
   3 METRE PRE - TERMINATED CABLE
8. HYLOMAR PL32 SEALANT TO BE APPLIED TO ALL CERTIFIED BLANKING PLUGS

MEDC Ltd, Colliery Road, Pinxton
Nottingham NG16 6JF, U.K.
Tel: +44 (0)1773 864100
Fax: +44 (0)1773 582800
e-mail:info@medc.com web:www.medc.com

DESIGNERS & MANUFACTURERS OF ELECTRICAL & ELECTRONIC EQUIPMENT & SYSTEMS FOR HAZARDOUS AREAS

ISSUES		ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED REMOVE ALL BURRS AND SHARP CORNERS MACHINE SYMBOLS THUS √	THIS DRAWING IS CONFIDENTIAL AND IS THE PROPERTY OF MEDC AND MUST NOT BE REPRODUCED EITHER WHOLLY OR PARTLY. ALL RIGHTS IN RESPECT OF PATENTS, DESIGNS AND COPYRIGHT ARE RESERVED	DRAWN BY: G. LAMB	DATE: 16.2.00	TITLE: GENERAL ARRANGEMENT XB9 IIC ATEX BEACON	
				CHECKED BY: M. SELDEN	DATE: 18.2.00		
				APPROVED BY: M. SELDEN	DATE: 18.2.00		
				SCALE: NTS	SIZE: A4	DRG No. 227-132	ISSUE A