

Certificate of Compliance

Certificate: 1136420 (LR 79122-1)

Master Contract: 178434

Project: 1261911

Date Issued: January 3, 2002

Issued to: MANUFACTURING ELECTRICAL
DESIGN CONSULTANTS LTD.
T/A MEDC
Colliery Rd.
Pinxton, Nottingham, NG1G 6JF
England
Attention: Mr. Daniel Hagin


The products listed below are eligible to bear the CSA Mark shown



Issued by:


D. Lippert

Authorized by:


Brian Rossborough
Operations Manager

PRODUCTS

CLASS 4818 02 - SIGNAL APPLIANCES - Audible - For Hazardous Locations

Class I, Groups A, B, C and D.

Model DB5 sounder, supply 24V dc, 15 mA max; intrinsically safe when connected through CSA Certified zener barrier rated 28V max, 300 ohms min, or 22V max, 150 ohms min.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	142-M1987	-	Process Control Equipment
CAN/CSA-C22.2 No.	157-92	-	Intrinsically Safe and Non-Incendive Equipment for Use in Hazardous Locations