

Certificate of Compliance

Certificate Number 082305E23759205NK21886
Report Reference E237592, Report Issued 06 August 2003
Issue Date 2005 August 23

Page 1 of 1



Issued to: **Medc**
Colliery Rd., Pinxton, Nottingham
NG16 6JF England, United Kingdom


*This is to certify that
representative samples of* **Junction Boxes**
Models JB10 and JB11

*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*


Standard(s) for Safety: UL 50, UL 60079-0, UL 60079-7; CSA-C22.2 No. 94
CSA-E60079-0, CSA-E60079-7


Additional Information: The product marking shall include the following information:
Class I, Zone 1 AEx e II; Ex e II.
Class I, Div. 2, Groups A, B, C and D

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle;  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: 
Michael Slowinski/Section Manager
Underwriters Laboratories Inc.

Reviewed by: 
Paul T. Kelly/Operations Manager
Underwriters Laboratories Inc.