



Northbrook Division
333 Pfingsten Road
Northbrook, IL 60062-2096 USA
www.ul.com
tel: 1 847 272 8800

MEDC
MR P OATES
COLLIERY RD
PINXTON
NOTTINGHAM
NG16 6JF ENGLAND UNITED KINGDOM

RE: Project Number(s) - 03NK762

Your most recent Certification is shown below. You may also view this information, or a portion of this information (depending on the product category), on UL's Online Certifications Directory at www.ul.com/database. Please review the text and contact the Conformity Assessment Services staff member who handled your project if revisions are required. For instructions on placing an order for this information in a 3 x 5-inch format, you may refer to the enclosed order form for UL Card Service.

BGYM7 August 15, 2003
Boxes-Junction and Pull For Use In Class I, Zone 0, 1, and 2 Hazardous Locations Certified for Canada

MEDC
COLLIERY RD PINXTON NOTTINGHAM, NG16 6JF
ENGLAND UNITED KINGDOM

E237592

Class I, Zone 1, AEx e IIC.
Nonmetallic junction boxes, Models JB10 and JB11 followed by a letter A, B, C, D, E, J, K, L, M, N or O, followed by number, followed by N or R or S, followed by 1, 2, 3 or 4, followed by N or E, followed by N, followed by N, B or C, followed by T, followed by N, W or Y, followed by N.

LOOK FOR LISTING MARK ON PRODUCT

