

# Certificate of Test

We hereby declare that the item described below  
has been tested by BSI and

complies with the requirements of

*BS EN 60529: 1992 Specification for Degrees of protection by enclosures (IP Code). For a classification of IP66, and IPX7. Protection against ingress of solid foreign objects (Dust tight), Protection against ingress of water (Powerful jetting) and Protection against ingress of water (Temporary immersion)*

The full details of the tests and the results are given  
in our Report No: 229/000021      Dated: 13 June 1997


Description of item tested:

*DB3/DB4 Unit*

Submitted by:

MEDC  
Colliery Road  
Pinxton  
Nottingham  
NG16 6JF

Certificate authorized by:



*J Hartley*

*Business Group Manager*

Title

Date

*13 June 1997*



Attention is drawn to the conditions under which this declaration is issued, namely:

1. The general and specific conditions of the BSI Testing House, Test Leaflet 1 apply in all respects. Copies of this leaflet are available on request.

2. This Declaration applies only to the particular sample tested and to the specific tests carried out as detailed in the report referred to above.

3. This declaration does not indicate any measure of Approval, Certification, Supervision, Control or Surveillance by BSI to this or any related product.