

- 1. TYPE DB4 & DB4L
- 2. CERTIFICATION IIC: BAS OoATEX2097X EExd IIC BAS OoATEX2098X EExde IIC T5 (ISW & BELOW), T4 (ABOVE ISW)
- 3. WEIGHT - EExd VERSION = 5.0 ± 0.3 kg EExde VERSION = 5.5 ± 0.3 kg
- 4. MATERIAL - ENCLOSURE, COVER & HOPIH - GRP.
- 5. OPTIONAL DUTY LABEL, LETTER SIZE 5 MAX
- 6. OPTIONAL TAG LABEL, LETTER SIZE 5 MAX.
- 7. TERMINALS SUITABLE FOR UPTO 2.5 mm² CABLE.

DO NOT SCALE

199-394



EExd UNIT

ISSUES		B. 09/10/02 PF C. 08/07/03 PF		GENERAL TOLERANCES		ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED		THIS DRAWING IS CONFIDENTIAL AND IS THE PROPERTY OF MEDC AND MUST NOT BE REPRODUCED EITHER WHOLLY OR PARTLY. ALL RIGHTS IN RESPECT OF PATENTS, DESIGNS AND COPYRIGHT ARE RESERVED.		DRAWN BY: M. SELDEN CHECKED BY: G. HODGKINS APPROVED BY: M. SELDEN		DATE: 18/08/00		TITLE		SHEET	
3.2		±0.25		±0.5		REMOVE ALL BURRS AND SHARP CORNERS		MACHINE SYMBOLS THUS		SCALE: A3		SITE: A3		DRG No. 199-394		ISSUE	
C		1		CUSTOMER GA		DB4 & DB4L		SPEAKERS		1		2		OF		C	

MEDC Ltd, Colliery Road, Farnham
Hampshire GU14 6JF, U.K.
Tel: +44 (0)1253 894100
Fax: +44 (0)1253 894101
e-mail: info@medc.com web: www.medc.com



DESIGNERS & MANUFACTURERS
OF ELECTRICAL & ELECTRONIC
EQUIPMENT & SYSTEMS FOR
HAZARDOUS AREAS



EEExde UNIT

DO NOT SCALE

MEDC

MEDC Ltd, Colliery Road, Piarton
Northampton NN16 6SF, U.K.
Tel: +44 (0)1173 861100
Fax: +44 (0)1173 522800
e-mail: info@medc.com web: www.medc.com

DESIGNERS & MANUFACTURERS
OF ELECTRICAL & ELECTRONIC
EQUIPMENT & SYSTEMS FOR
HAZARDOUS AREAS

ISSUES	09/10/02 PF	08/07/03 PF	<div> <div> GENERAL TOLERANCES UNOS </div> <div> ± 0.25 $\pm 0.5^\circ$ 3.2  </div> </div>	<div> <div> ALL DIMENSIONS ARE IN MILLIMETERS UNLESS OTHERWISE STATED </div> <div> REMOVE ALL BURRS AND SHARP CORNERS </div> </div>	<div> <div> THIS DRAWING IS CONFIDENTIAL AND IS THE PROPERTY OF MEDIC AND MUST NOT BE REPRODUCED EITHER WHOLLY OR PARTLY. ALL RIGHTS IN RESPECT OF PATENTS, DESIGNS AND COPYRIGHT ARE RESERVED. </div> <div> MACHINE SYMBOLS THIS  </div> </div>	<div> <div> DATE: 18/08/00 DATE: 18/08/00 DATE: 18/08/00 </div> <div> DRAWN BY: M.SELDEF CHECKED BY: G.HOOGMOED APPROVED BY: M.SELDEF </div> <div> DATE: 18/08/00 DATE: 18/08/00 DATE: 18/08/00 </div> </div>	<div> <div> TITLE CUSTOMER GA DB4 & DB4L SPEAKERS </div> <div> DATE: 18/08/00 DATE: 18/08/00 DATE: 18/08/00 </div> </div>	<div> <div> SIZE: A3 UNITS </div> <div> DRAW N°: 199-394 ISSUE: C </div> </div>	<div> <div> SHEET 2 OF 2 </div> </div>
--------	-------------	-------------	--	---	--	---	---	---	--




TRANSFORMER TAPPING / TERMINAL NUMBER	POWER			
	25W	20W	15W	8W
1:2	25.0	20.0	15.0	8.0
2:3	12.5	10.0	7.5	4.0
3:4	6.0	6.0	5.0	2.0
1:3	4.0	5.0	4.0	1.5
2:4	2.0	2.0	2.0	0.7
1:4	1.0	1.5	0.8	0.4

**OF ELECTRICAL & ELECTRONIC
EQUIPMENT & SYSTEMS FOR
HAZARDOUS AREAS**



ISSUES	
B. REPLOTTED	08/08/00 MDS
C. 03/01/03 PF	D. 20/04/04 PF

ALL INFORMATION CONTAINED HEREIN IS UNCLASSIFIED DATE 06-19-2008 BY 60322 UCBAW	ALL RIGHTS IN RESPECT OF PATENTS, DESIGNS AND COPYRIGHT ARE RESERVED
THIS DOCUMENT CONTAINS NEITHER RECOMMENDATIONS NOR CONCLUSIONS OF THE NATIONAL BUREAU OF STANDARDS AND TECHNOLOGY	

TITLE

WIPING DIAGRAM
4 WIRE INPUT TRANSFORMER
DB4

DRG No.	199-315	ISSUE	D
---------	---------	-------	---