

# Certificate of Compliance

Certificate Number 20071116-E203310  
Report Reference E203310, 2001 March 30  
Issue Date 2007 November 16

Page 1 of 1



**Issued to:** **Medc**  
Colliery Rd, Pinxton, Nottingham  
NG16 6JF England, United Kingdom

*This is to certify that  
representative samples of*

## **Audible-Signal Devices**


Audible signal device, Model DB3 and speaker, Model DB4, for use in Class I, Division 2, Groups A, B, C, and D; Class II, Division 2, Groups F and G; Class I, Zone 1, AEx d IIC; Class I, Zone 1 Ex d IIC, hazardous locations.

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

**Standard(s) for Safety:** UL 464, Seventh Edition (DB3) and UL 1480, Fifth Edition (DB4), UL 1604, Third Edition; UL 60079-0, Fourth Edition; UL 60079-1, Fifth Edition; CSA E60079-0:1998; CSA E60079-1:2001.

**Additional Information:** Marking shall include the Listee's Name, Model Number, Electrical Ratings including voltage, wattage and amps, Ambient Range and Temperature Code.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers;  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: *Russell L. Filip*  
Russell L. Filip/Staff Engineer  
Underwriters Laboratories Inc.

Reviewed by: *Paul T. Kelly*  
Paul T. Kelly/Operations Manager  
Underwriters Laboratories Inc.