

UNDERWRITERS LABORATORIES INC.®



CERTIFICATE OF COMPLIANCE

- (1)
- (2) UL Certificate Number 02.05615-5
- (3) This certificate is issued for: Visual-Signal Devices
Type/Model: XB11, XB12, FB12
- (4) Issued to: MEDC Ltd.
Colliery Rd.
Pinxton
Nottingham
NG16 6JF England United Kingdom
- (5) Report References: E187894, Issued 28 January 2000
E187894, Issued 6 June 2001
- (6) This product has been investigated by Underwriters Laboratories Inc.® in accordance with the following Standard(s) for Safety indicated on this Certificate:

UL 1638, UL 2279
CSA-E79-0-95, CSA-E79-1-95
- (7) The product marking shall include the following information:

Class I, Zone 1, AEx d IIB; Ex d IIB
Class I, Division 2, Groups C and D
- (8) Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for the US and Canada.


The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers; "UL" with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Signed:

Issued:

11 March 2002


Paul T. Kelly
Associate Manager

This certificate may only be reproduced in its entirety and without alterations.

Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096 (USA)
Phone: Int. + 847 664 2326 Fax: Int. + 847 313 2326 E-mail: hazloc@ul.com Website: <http://www.ul.com/hazloc/>

UNDERWRITERS LABORATORIES INC.®



APPENDIX I

To Certificate of Compliance 02.05615-5

This approval applies to:

Visual-Signal Devices

Issued to:

MEDC Ltd.
Colliery Rd.
Pinxton
Nottingham
NG16 6JF England United Kingdom

(01) Type/Model:

Beacon Lights, Model XB11

Ambient Temp. Range: -55° C to 55° C

Electrical Ratings: 24 V dc, 8 W;
110 V ac, 50/60 Hz, 11 W;
240 V ac, 50/60 Hz, 18 W

Markings include the following:

Class I, Zone 1, AEx d IIB, Ex d IIB
Class I, Division 2, Groups C and D; T5

This Appendix is to be used in conjunction with Certificate of Compliance No. 02.05615-5

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Signed:

Issued: 11 March 2002

Paul T. Kelly
Associate Manager

This certificate may only be reproduced in its entirety and without alterations.

Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096 (USA)
Phone: Int. + 847 664 2326 Fax: Int. + 847 313 2326 E-mail: hazloc@ul.com Website: <http://www.ul.com/hazloc/>

UNDERWRITERS LABORATORIES INC.®



APPENDIX II

To Certificate of Compliance 02.05615-5

This approval applies to:

Visual-Signal Devices

Issued to:

MEDC Ltd.
Colliery Rd.
Pinxton
Nottingham
NG16 6JF England United Kingdom

(02) Type/Model:

Beacon Lights, Model XB12

Ambient Temp. Range: -55° C to 55° C

Electrical Ratings: 24 V dc, 34 W;
110 V ac, 50/60 Hz, 34 W;
240 V ac, 50/60 Hz, 44 W

Markings include the following:

Class I, Zone 1, AEx d IIB, Ex d IIB
Class I, Division 2, Groups C and D; T4

This Appendix is to be used in conjunction with Certificate of Compliance No. 02.05615-5

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Signed:

Issued:

11 March 2002

Paul T. Kelly
Associate Manager

This certificate may only be reproduced in its entirety and without alterations.

Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096 (USA)
Phone: Int. + 847 664 2326 Fax: Int. + 847 313 2326 E-mail: hazloc@ul.com Website: <http://www.ul.com/hazloc/>

UNDERWRITERS LABORATORIES INC.®



APPENDIX III

To Certificate of Compliance 02.05615-5

This approval applies to:

Visual-Signal Devices

Issued to:

MEDC Ltd.
Colliery Rd.
Pinxton
Nottingham
NG16 6JF England United Kingdom

(03) Type/Model:

Beacon Lights, Model FB12

Ambient Range: -55° C to 55° C; T4
-55° C to 40° C; T5

Electrical Ratings: 120 V ac, 60 W

Markings include the following:

Class I, Zone 1, AEx d IIB, Ex d IIB
Class I, Division 2, Groups C and D

This Appendix is to be used in conjunction with Certificate of Compliance No. 02.05615-5

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Signed:

Issued: 11 March 2002

A handwritten signature in cursive script, appearing to read 'Paul T. Kelly'.

Paul T. Kelly
Associate Manager

This certificate may only be reproduced in its entirety and without alterations.

Underwriters Laboratories Inc., 333 Pfingsten Road, Northbrook, IL 60062-2096 (USA)
Phone: Int. + 847 664 2326 Fax: Int. + 847 313 2326 E-mail: hazloc@ul.com Website: <http://www.ul.com/hazloc/>